Ownership matrix	**USQ # 21-0226-D**

TABLE OF CONTENTS

TABLE OF TABLES

1.0 PURPOSE AND SCOPE

(7.1.1, 7.1.2)

This procedure describes the process for implementing best known safe work practices for dealing with potentially flammable atmospheres by:

- Determining that activities and associated portable (not installed) equipment and materials meet applicable Ignition Control requirements, and
- Determining safe work practices and obtaining their approvals when ignition source control (ISC) requirements are applicable.

Above and throughout this procedure, Ignition Control means controlling either the concentration of flammable gas, or controlling potential ignition sources. Ignition Source Control means controlling potential ignition sources.

The term "activity," as used in this standard, refers to work that might take place in a location requiring ignition controls. Activities may include measures other than control of ignition sources by use of an approved work practice, such as verified evaluations demonstrating low concentrations of flammable gas. The term "approved work practice," as used in this standard, is an activity that has been determined free of ignition sources.

This procedure is applicable to development of Level 1, 2 and 3 Work Packages (TFC-OPS-MAINT-C-01), PMIDs, and those operations Technical Procedures that require ignition controls for potentially flammable atmospheres for Tank Farms and 242-A Evaporator, i.e., that involve more than routine operations and maintenance of equipment, such as breaching of radioactive systems, or energizing equipment or wiring in a classified location.

This procedure is not applicable to any Work Packages, PMIDs, or Technical Procedures for work at Effluent Treatment Facility (ETF), Liquid Effluent Retention Facility (LERF), Treated Effluent Disposal Facility (TEDF), 222-S Laboratory, nor work at any non-nuclear facility listed in Table 1.

This procedure is not applicable to installed equipment. It does not apply to design, procurement, nor configuration control of new equipment nor modifications to existing installed equipment but does apply to installation activities. Refer to TFC-ENG-STD-45 for requirements for design of equipment for installation in potentially flammable atmospheres.

This procedure is not required for normal operation, calibration, or non-intrusive adjustment of installed equipment – normal meaning as intended by the manufacturer and as approved by the design authority, and subject to operations procedures and administrative controls or restrictions. Normal operation excludes maintenance, intrusive inspections, and any other disassembly or alteration beyond removal of access covers for normal calibration and testing.

This procedure is not required for work packages within the work scope and responsibility of a prime contractor service organization, as described in TFC-OPS-MAINT-C-01, Section 1.1, and as specified in Tank Operations Contract Section J.3 (e.g., Fire Systems Maintenance, Refrigerated Equipment Service, etc.). These work packages are prepared in accordance with the prime contractor's work processes and hazards analysis. A list of other prime contractor activities performed in WRPS-controlled facilities, which have been USQ evaluated, is

maintained by WRPS Nuclear Safety and is available on the Intranet on the Safety Basis Website under USQ List of Procedures and Activities Performed by Others.

This procedure supports implementation of the following technical safety requirements (TSR).

From HNF-SD-WM-TSR-006, Tank Farm TSRs:

- LCO 3.1, "DST Primary Tank Ventilation Systems"
- LCO 3.2, "SST Steady-State Flammable Gas Control"
- LCO 3.5, "DST 241-AY-102 Annulus Flammable Gas Control"
- LCO 3.6, "DCRT Steady-State Flammable Gas Control"
- LCO 3.7, "DST 241-AY-102 Flammable Gas Monitoring Control"
- LCO 3.11, "DST Annulus High Level Alarm (Automation)"
- AC 5.8.2, "Flammable Gas Controls"
- AC 5.9.2, "Ignition Controls."

From HNF-15279, Evaporator TSRs:

- AC 5.8.1, "Flammable Gas Controls for Waste Feed Transfer Piping, Waste Slurry Transfer Piping and C-A-1 Vessel Drain (Dump) Piping (SAC)."
- AC 5.9.2, "Ignition Controls (AC Key Element)."

2.0 IMPLEMENTATION

This procedure is effective on the date shown in the header.

Revisions of this procedure or associated forms are expected to be improvements in clarity of requirements, efficiency of use, and reduction in potential for errors. Revisions are not retroactive to forms that are in process or that have already been approved by the time this procedure or the forms are released as a new revision.

Any exception to the above that requires a review of existing approved forms, will be specifically communicated and addressed prior to release of an affected procedure or form revision.

Revision H added the requirement in Section 4.3 for PMIDs to attach completed form(s) (A-6003-774 and A-6003-749) in SmartPlant® Foundation (SPF). For existing PMIDs, it is acceptable to place the completed form(s) directly into the work package while the change to the PMID is processed.

3.0 RESPONSIBILITIES

The Chief Engineer designates each role in this section.

For the responsibilities below, equipment that is labeled in accordance with TFC-ENG-STD-13, Section 3.3.1, and work practices, tools, materials, or equipment with evaluations that are listed in tables attached to TFC-ENG-STD-13 are not considered to be new equipment, nor new work practices; Section 4.0 details the responsibilities and the process for making this determination.

Each of the responsibilities listed in Sections 3.5, 3.6 and 3.7 might elsewhere be called a Subject Matter Expert (SME), where the context is independent of required technical discipline. However, an SME is not an authority having jurisdiction (AHJ), nor an EDL, nor a nuclear safety

engineer, each of those designated by the Chief Engineer specifically for this responsibility as required by Tank Farms TSR 5.9.2-1.

3.1 Originator

Performs Ignition Source Controls pre-screening of:

- ALL Level 1, 2 and 3 work packages and PMIDs for Tank Farms and 242-A Evaporator. Work packages for ETF, LERF, TEDF, 222-S Laboratory, and Non-Nuclear Facilities listed in Table 1, are excluded.

- Specific Tank Farms and 242-A Evaporator technical procedures that require ignition controls for potentially flammable atmospheres. These are the procedures that involve more than routine operations and maintenance of equipment, such as breaching of radioactive systems, or energizing wiring that penetrates into a classified location and was modified or previously de-energized, or using portable test equipment to connect to wiring that penetrates from outside into the interior of a classified location. Examples of test equipment with intrusive wiring include, but are not limited to, thermocouple readings and manual tape readings.

3.2 Engineer

- Prepares detailed Ignition Source Control screening of work packages and specific PMIDs and technical procedures.

- Is an Engineering Technical Staff qualified engineer.

3.3 Checker

- Checks and reviews detailed Ignition Source Control screening work packages, PMIDs, and specific technical procedures.

- Is an Engineering Technical Staff qualified engineer.

The Engineer and Checker may not be the same individual.

3.4 National Fire Protection Association Authority Having Jurisdiction for NFPA70E, "Electrical Safety in the Workplace"

Approves all new electrical equipment and work controls, including enforcement of electrical codes and standards that require Ignition Source Controls or Ignition Controls, and approval of new work practice safety determinations.

3.5 Subject Matter Expert for Non-Electrical Ignition Source Controls

See Section 5.0 Definitions for a list of various subject matter experts (SMEs).

Approves all new non-electrical equipment subject to Ignition Source Control requirements of TFC-ENG-STD-13, requirements for ignition controls, including enforcement of ignition source control codes and standards, and approval of new work practice safety determinations.

3.6 Nuclear Safety Engineer

Approves all new work practice safety determinations for new equipment or new work controls.

4.0 PROCEDURE

(7.1.1, 7.1.2)

This procedure is required for specific Tank Farms and 242-A Evaporator technical procedures that involve more than routine operations of approved installed equipment, such as breaching of radioactive systems, in classified locations as identified in TFC-ENG-STD-13.

Normal operation of installed equipment in classified locations was approved as part of the equipment selection and evaluation in accordance with TFC-ENG-STD-45. Refer to TFC-ENG-STD-45, Section 2.0, Implementation, for approved equipment for normal operation as installed before June 15, 2017. Refer to TFC-ENG-STD-45, Section 3.3, Design Requirements, and Section 3.4, Verification Requirements, for requirements for design and normal operation of equipment for installation in potentially flammable atmospheres after June 15, 2017.

4.1 Ignition Source Control Pre-Screening

NOTE: It is essential to use the associated form instructions in order to be able to complete site form A-6003-774 accurately.

Originator

1. Obtain a copy of site form A-6003-774, "Ignition Source Control Requirements Screening of Work Activities and Equipment Used in Performing Work Activities," and complete applicable sections using the form instructions (A-6003-774i).

2. Complete Section I of A-6003-774 to determine if a detailed Ignition Source Control screening is required.

3. If the answers to all questions in Section I are "No", then perform the following:

   NOTE: Ignition Source Controls are not required for the work activity or procedure, and completion of Sections II, III, or IV is NOT required.

   a. Complete the form by approving in Section I (only the approval of the originator is required to complete the form).

   b. Proceed to Section 4.3 to include the completed form in the work package.

4. If any answer to the questions in Section I is "Yes," then perform the following:

   NOTE: Additional screening is required to determine if Ignition Source Controls are required.

   a. Complete Section I by approving the signature block.

   b. Provide the form to the Engineer responsible for the work activity or technical procedure to perform a more detailed screening.

   c. Proceed to Section 4.2.

4.2 ISC Screening

NOTE: Section II of form A-6003-774 is used to determine if the work is being performed in a specific location subject to Ignition Source Controls.

Engineer

1. Complete Section II of form A-6003-774 to determine if the work activity is being performed in a location subject to Ignition Source Controls (as identified in Table 1 of TFC-ENG-STD-13).

2. If the answer to any question in Section II is "Yes," proceed to step 6 to complete the remainder of the form.

NOTE 1: Ignition Source Controls are NOT required.

NOTE 2: Completion of Section III is NOT required.

3. If the answer to all questions in Section II is "No," complete the form by approving in Section IV.

Checker

4. Review the form and approve in Section IV to indicate agreement that Ignition Source Controls are not required.

Engineer

5. Proceed to Section 4.3 to include completed form in work package.

NOTE: Section III of form A-6003-774 is used to determine the applicable Ignition Source Control set for the location of the work activity or to determine that Ignition Source Controls are not applicable. When not applicable, that must be based on a verified evaluation, or based on a report approved in accordance with HNF-IP-1266, Section 5.8.2, Subsections 3.B.2.c and 3.B.1.c (not required to be approved by any ignition source control SME identified in Sections 3.0 and 3.5, as ignition source controls is then not applicable).

Engineer

6. Complete Sections III of form A-6003-774.

7. If the result of Section III is that Ignition Source Controls are required and the applicable Ignition Source Control set has been identified, proceed to Step 11 to complete an Ignition Source Control Evaluation Worksheet (A-6003-749).

8. If the result of Section III is that ISC is not required because a concentration of 25% of the LFL cannot occur, completion of an Ignition Control Evaluation Worksheet (A-6003-749 is NOT required.

    a. Document the basis for not applying an Ignition Source Controls in the Comments field in Section III, and as necessary for verification, include any necessary controls in the work instructions/procedure steps, during Section 4.3 of this procedure.

    b. Complete the form by approving in Section IV.

Checker

9. Review the form and approve in Section IV to indicate agreement that Ignition Source Controls are not applicable.

Engineer

10. Proceed to Section 4.3 to include completed form in the work package.

NOTE: An Ignition Source Control Evaluation Worksheet (A-6003-749) documents the specific Ignition Source Control requirements that apply to the activity and documents that the work practices are compliant.

Engineer

11. Prepare an Ignition Source Control Evaluation Worksheet (site form A-6003-749).

    a. Complete Section I to document the individual work practices, equipment, and materials used to perform the work or procedure; the Ignition Source Control Set that they must meet; their acceptability; specific conditions or controls to be met for their acceptability; the basis for the controls and acceptability (e.g., FGEAB Report, Technical Evaluation, or specific compliant equipment labeling).

12. If Ignition Source Controls may be discontinued during the work practice after monitoring of flammable gas concentration, perform the following:

    a. Complete Section II of form A-6003-749 to verify that there is no potential for a gas release event to result in a flammable concentration.

    b. Provide work control details (in accordance with Section 4.3) to ensure that sampling be conducted in accordance with TFC-ESHQ-FP-STD-05.

13. Submit completed form(s) to the Checker.

Checker

14. Review the completed form(s) to ensure that all flammable gas requirements are satisfied, and that any equipment not labeled in accordance with TFC-ENG-STD-13, Section 3.3.1, nor previously approved by an FGEAB Report or Technical Evaluation (most such approvals are listed in TFC-ENG-STD-13), or any activity, tools, or material not previously approved by an FGEAB Report or Technical Evaluation, is approved by the SME or AHJ, and the Nuclear Safety Engineer (NSE) (this procedure Step 15).

Engineer

15. For any work practices, including equipment or material associated with the work, not labeled in accordance with TFC-ENG-STD-13 nor previously approved by an FGEAB or Technical Evaluation, prepare/approve a Technical Evaluation in accordance with TFC-ENG-FACSUP-C-03 that includes:

    - Information required by TFC-ENG-STD-13 for determining and approving safe work practice
    - Evaluation of the work practice as safe for a stated generic hazard classification, i.e. Class I Division 1 Group B, excluding reference to any specific TOC system or location
    - Comprehensive listing of every activity/step of the work practice that is critical for ignition source control safety in the 'Enabling Assumptions' section of the technical evaluation
    - The SME or AHJ, and NSE as additional required approvals.

NOTE: Where ignition controls are required, as indicated by any "Yes" response on Section II of form A-6003-774, a completed form A-6003-749 verifying the work practice, equipment, or material was appropriately labeled or previously approved, or verifying that a new Technical Evaluation has been approved, is suitable supporting documentation for release of the Work Package, PMID, or Technical Procedure. It is possible that both previously approved and newly approved Technical Evaluations are needed to cover an assortment of previously approved and new activities, equipment, and materials in the same work package, PMID, or procedure.

16. Ensure the form is complete and all applicable approval signatures for the form(s) have been obtained.

4.3 Documentation and Record Completion

Originator or Engineer

1. For Work Packages (including PM Work Packages that require supplemental work instructions), provide work control details necessary to implement ignition controls (including verification of ignition controls identified in Section 4.2 steps 9a and 14b, and any conditions identified in the Condition column of form A-6003-749), and a copy of supporting documentation including forms (A-6003-774 and A-6003-749) to the Work Planner for inclusion in the Work Order Review and Approval Checklist (WORA), the work package, and capture in IDMS records when the work package is completed and scanned.

2. For PMIDs:

    a. If the PMID is new or being revised, attach PDFs of completed, signed forms to the PMID in SPF, and include in the Record PDF to ensure completed forms are included with the PMID in IDMS (These completed screening forms will also be attached in Enterprise Asset Management (EAM), included in the work package, and captured in IDMS records when the package is completed and scanned).

    b. If the PMID is not being revised, provide a copy of the completed screening form to the work planner to be included in the work package and captured in IDMS records when the package is completed and scanned.

3. For technical procedures, provide work control details necessary to implement ignition controls (including verification of ignition controls identified in Section 4.2 steps 9a and 14b, and any conditions identified in the Condition column of form A-6003-749), and a copy of supporting documentation including forms (A-6003-774 and A-6003-749) to the technical procedure originator as supporting documents for the technical procedure.

Engineer

4. For activities requiring ignition controls, during work package, PMID, or technical procedure development, ensure that all applicable Ignition Controls and Ignition Source Controls, including call out of specific required equipment, are clearly identified in the work instructions/procedure steps.

5. If the ignition control does not require Ignition Source Controls, ensure the call out of required verification of Ignition Controls, from Section III of form A-6003-774, in the work instructions/procedure steps.

6. If a Technical Evaluation for a work practice was approved by appropriate SMEs, ensure that the Electrical Engineering Discipline Lead was on distribution of release of the Technical Evaluation, or send a notification of release by email.

NOTE: The Technical Evaluation may be relied upon once released and prior to inclusion in TFC-ENG-STD-13.

Electrical Engineering Discipline Lead

7. For any work practice, equipment, or material not previously listed in TFC-ENG-STD-13, revise the Tables of TFC-ENG-STD-13 to list the new Technical Evaluation with a brief summary of the basis for approval of the work practice, equipment, or material.

    a. Include all "Enabling Assumptions" from the technical evaluation in the "Conditions" column of the table.

5.0 DEFINITIONS

AHJ. Authority Having Jurisdiction for NFPA70E.

AMCA. Air Movement and Control Association.

API. American Petroleum Institute.

ATEX. Appareils destinés à être utilisés en **AT**mosphères **EX**plosives.

Gas Trapping. May contain flammable gases generated by tank wastes, including flammable gases generated by corrosion in a tank-waste environment, and that have a configuration that can trap flammable gases and accumulate a flammable gas concentration > 25% LFL.

IDMS. Integrated Document Management System.

Ignition Controls. Controls to assure that a location is free of ignitable mixtures of flammable gas, or to ensure that no ignition source is present in the location.

Ignition Source Controls (ISCs). Controls to ensure that equipment, tools, and work activities are not an ignition source in a location with potentially ignitable gas.

NFPA. National Fire Protection Association.

PMID. Preventive Maintenance Identification Document

Subject Matter Expert. Designated by Chief Engineer, including electrical AHJ, Nuclear Safety Engineer, and non-electrical SME. The non-electrical SME covers electrostatic issues.

SPF. SmartPlant® Foundation.

6.0 RECORDS

The following records are generated during the performance of this procedure:

- Site form A-6003-774, "Ignition Source Control Requirements Screening of Work Activities and Equipment Used in Performing Work Activities"
- Site form A-6003-749, "Ignition Control Evaluation Worksheet."

The record custodian identified in the Company Level Records Inventory and Disposition Schedules (RIDS) is responsible for record retention in accordance with TFC-BSM-IRM_DC-C-02.

7.0 SOURCES

7.1 Requirements

7.1.1 HNF-15279, "242-A Evaporator Technical Safety Requirements."

7.1.2 HNF-SD-WM-TSR-006, "Tank Farms Technical Safety Requirements."

7.2 References

7.2.1 API RP-2003, "Protection Against Ignitions Arising Out of Static, Lightning, and Stray Currents."

7.2.2 HNF-IP-1266, "Tank Farms Operations Administrative Controls "

7.2.3 HNF-SD-WM-HC-017, "NFPA Flammable Vapor and Gas Hazard Classification for the Tank Farms."

7.2.4 NFPA 70E, "Electrical Safety in the Workplace."

7.2.5 NFPA 77, "Recommended Practice on Static Electricity."

7.2.6 RPP-RPT-58290, "NFPA Flammable Vapor and Gas Hazard Classification for the 242-A Evaporator."

7.2.7 RPP-RPT-61283, "Tank Side Cesium Removal Hazardous Area Classification Report."

7.2.8 TFC-ENG-FACSUP-C-03, "Technical Evaluations."

7.2.9 TFC-ENG-STD-13, "Ignition Controls for Work Controls in Potentially Flammable Atmospheres."

7.2.10 TFC-ESHQ-FP-STD-05, "Flammable Gas Monitoring."

7.2.11 TFC-OPS-MAINT-C-01, "Tank Operations Contractor Work Control."

Table 1. Non-Nuclear Facilities (This procedure is not applicable).

Building #	Description
611	Cold Test Facility Warehouse Horn Rapids Road
672	Cold Test Facility Admin Bldg. Horn Rapids Road
674	Cold Test Facility Briefing Center Horn Rapids Road
2506E2	TELECOMMUNICATIONS
2025E[3]	200 Area Effluent Treatment Facility (ETF)
2025EA	EFFLUENT TREATMENT OFFICE BUILDING
2025EC71	EFFLUENT TREATMENT LCU BUILDING
2025ED	PURGEWATER UNLOADING FACILITY
2101HV	HWVP Warehouse
2102HV	MATERIAL MANAGEMENT PAD
2105HV	Sprung Dome Storage Structure East of 2704HV
2106HV	HWVP Storage - Sprung Dome/North of 2704HV
2109E	BOTTLE STORAGE AT AP TANK FARM
2125E	ETF STORAGE SHELTER N OF 2025E
212S	COVERED GAS BOTTLE STORAGE
213B	Laydown Yard North of 2704HV
214C	COVERED MAINTENANCE WORK LOCATION
214F	EQUIPMENT LAYDOWN SHELTER SW OF MO595
214G	EQUIPMENT LAYDOWN SHELTER SW OF MO595
214J	EQUIPMENT STORAGE
214K	EQUIPMENT STORAGE
216E43[1]	Control Structures Treated Effluent Disposal Facility (TEDF)
217AN	SCBA BOTTLE HANDLING TENT AT AN FARM
217AP	AP FARM BOTTLE CHANGE TENT
217AX	AX COOL DOWN TENT
217AZ	AZ-301 TANKER TENT ENCLOSURE
217C	C FARM COOL DOWN TENT
218A	Conditioned Storage Building
222S	CENTRAL ANALYTICAL LABORATORY
222SB	SOUTH FILTER BUILDING
222SC	NORTH FILTER BUILDING
222SE	LAB EXHAUST FILTER BUILDING
222SH	OFFICE AND CHANGE ROOM - N SIDE OF 222S
2237E	Construction Electrical Shop
2258E	STORAGE BLDG BEHIND A-FARM COMPOUND
225E	TEDF PUMP STATION 2 - LOCAL UNIT 55C-10
225WB	TEDF - LOCAL CONTROL UNIT 55C-22
227S	Lab Conditioned Storage Building/South of 222-S
229E	OIL STORAGE SHED N OF 272AW
241A201	EMER COOLING WATER STG TANK - SE OF 202A
241AP801	WATER SERVICE BUILDING
241AW801	WATER SERVICE BUILDING
241AZ701	STANDBY DIESEL GENERATOR BUILDING

Table 1. Non-Nuclear Facilities (This procedure is not applicable). (cont.)

Building #	Description
241TX701	LAUNDRY STORAGE FACILITY
2420 StvCn	2420 Stevens Center Blvd. Office building.
2425 StvCn	2425 Stevens Center Blvd. Office building.
242AL11	LERF STORAGE BUILDING - N OF 242A
242AL11[2]	Liquid Effluent Retention Facility (LERF) Storage Building
242AL71	LERF INSTRUMENT BUILDING
242T601	Chemical Makeup Building
242W	SODIUM STORAGE YARD
243G81	GPF - WATER SERVICE BUILDING
243G9	GPF ELECTRICAL SUBSTATION GROUT
2440 StvCn	2440 Stevens Center Blvd. Office building.
2506W4	TELECOMMUNICATIONS - AT 222S
2620Fermi	2620 Fermi Ave. Office building.
2703E	Maintenance Shop at 4th and Buffalo.
2704HV	TWRS Office Building
2704S	Lab Office Building
2705S	Lab Office Building
2707SX	Carpenter Shop Cooper Ave
2713S	Lab Office Building
2713WB	Regulated Garage and Heavy Equipment Repair
2715AW	Tank Farm Staging/Storage Facility
2715WA	Tank Farm Storage/Staging Facility
2716S	LABORATORY STORAGE
2727WA	Carpenter Shop NE of 2727W
272AW	Maintenance/Electrical Shop
272EA	Change Shelter NE Corner of 272AW
272EA	SWP STORAGE SHELTER - NE CORNER OF 272AW
272S	Maintenance Shop
272WA	Tank Farm Support Facility
2734S	LIQUID NITROGEN STORAGE FACILITY
274AW	OFFICE BUILDING
2750E	Office Building
2752E	Training/Office Building
2766E	Construction Laborers Shop
2767E	Construction Carpenter Shop
277A	Construction Fabrication Shop W of 241AZ Tank Farm
278AW	Mask Fit Station
279W	STORAGE
2904AR	COOLING WATER SAMPLER MONITORING SYSTEM
291AR	EXHAUST AIR FILTER STACK BUILDING
622S	FIELD LYSIMETER TEST FACILITY
851 SmartPk	Office building
MCC004	OFFICE CONNEX FOR WRPS CONSTRUCTION
MO027	Office trailer – at 272S North of 272S

Table 1. Non-Nuclear Facilities (This procedure is not applicable). (cont.)

Building #	Description
MO098	Mobile Office Facility West of 244AR
MO1142	Mobile Office Trailer SW of C-Farm
MO1145	Mobile Office Trailer SW of C-Farm
MO116	Cold Test Facility Control Trailer Horn Rapids Road
MO143	C Farm Restroom Trailer
MO144	AW Trailer - Phase II 8' x 30'; West of 272-AW
MO145	RESTROOM TRAILER E OF MO195
MO146	Field Storage/Sampling Trailer South of TC272HV
MO147	Field Storage/Sampling Trailer South of TC272HV
MO148	ETF Tool Crib Trailer South of 2025EA
MO149	AW Trailer - Phase II Double-Wide; West of 272-AW
MO150	AW Trailer - Phase II Double-Wide; West of 272-AW
MO151	AW Trailer - Phase II Double-Wide; West of 272-AW
MO156	AW Women's Shower Trailer Double-Wide; SE of 274-AW
MO157	AW Men's Shower Trailer Double-Wide; SE of 274-AW
MO158	Office Trailer East of MO284
MO159	Office Trailer SE of MO283 at East end of Grout Dr.
MO161	RESTROOM / SHOWER TRAILER - NW OF 222S
MO163	Mobile Office Facility West of 244AR
MO164	Mobile Office Facility West of 244AR
MO173	Mobile Office Facility West of 244AR
MO174	Mobile Office Facility West of 244AR
MO180	MOBILE OFFICE AT 213B LAYDOWN YARD
MO193	CHANGE TRAILER - W OF AY TANK FARM
MO194	OFFICE TRAILER NORTH OF 209E ON 7TH ST
MO195	OFFICE TRAILER NORTH OF 209E ON 7TH ST
MO211	OFFICE TRAILER - NE OF C FARM
MO2158	Office Trailer 272WA Support
MO2171	Lab Mobile Office
MO2172	242S Personnel Decontamination Trailer
MO2180	OFFICE TRAILER AT SY FARM
MO2192	MOBILE OFFICE TRAILER EAST OF 222S
MO2193	LUNCH ROOM TRAILER SW OF SX FARM
MO2194	CHANGE TRAILER SW CORNER OF SX FARM
MO2219	Maintenance Supervisor Trailer
MO2239	MOBILE OFFICE W OF 218A
MO2240	Office Trailer - S of AW Farm
MO2241	Office Trailer - S of AW Farm
MO2242	Office Trailer - S of AW Farm
MO2243	Office Trailer - S of AW Farm
MO2244	Decon Trailer - E of Buffalo at 241AZ701
MO2249	A/AX INGRESS CHANGE TRAILER
MO2251	OFFICE TRAILER EAST OF 242A EVAPORATOR
MO2254	OFFICE TRAILER S OF MO131

Table 1. Non-Nuclear Facilities (This procedure is not applicable). (cont.)

Building #	Description
MO2255	OFFICE TRAILER S OF MO131
MO2350	Restroom Trailer - SW of 2715AW
MO2350	RESTROOM TRAILER - SW OF 2715AW
MO251	ETF Ops Trailer
MO252	Office Trailer East of 2101M
MO2522	Shower Trailer - E of Grout Dr
MO253	Office Trailer East of 2101M
MO266	AW Trailer Double-Wide; South of 272-AW
MO267	AW Trailer Double-Wide; South of 272-AW
MO268	Office Trailer - At 272AW Tank Farms
MO269	Material Coordinator Trailer South of 2025E
MO272	Construction Craft Lunchroom South of 277A
MO280	Office Trailer - At WSCF
MO280	OFFICE TRAILER - AT WSCF
MO282	Grout Trailer Double-Wide; West of 243G1
MO283	Grout Trailer Double-Wide; West of 243G1
MO284	Grout Trailer Double-Wide; West of 243G1
MO291	Lab Mobile Office Ten-Wide Trailer
MO295	CHANGE TRAILER - AT SY TANK FARM
MO296	CHANGE TRAILER - NEAR 241SY EVAPORATOR
MO297	CHANGE TRAILER - W OF 241U
MO297	CHANGE TRAILER - W OF 241U
MO298	CHANGE TRAILER - SX FARM
MO299	CHANGE TRAILER - BX FARM
MO409	Mobile Office - Material Storage East of 222S
MO447	Mobile Office South of CR Farm
MO450	SY Farm Storage Trailer North of 241-SY
MO493	AW Trailer Double-Wide; SE of 272-AW
MO497	OFFICE TRAILER - N OF 241AN
MO511	AW Conference Trailer Double-Wide; South of 272-AW
MO512	CHANGE TRAILER - NW OF 241C TANK FARM
MO513	CHANGE TRAILER - AT 241AY TANK FARM
MO523	ACES Station / Office Trailer SW of C-Farm
MO524	Office Trailer SW of C-Farm
MO525	C Farm Office Trailer SW of C Farm
MO527	Restroom Trailer 8' x 30'; Buffalo Ave
MO528	Restroom Trailer 8' x 30'; Buffalo Ave
MO531	Construction Office Trailer/SW of C Farm
MO533	AW Office Trailer Double-Wide; South of 272-AW
MO563	Vadose Zone Lunchroom Trailer/South of 242S
MO564	OFFICE TRAILER - NE OF SY FARM
MO567	MOBILE OFFICE NE OF 241C TANK FARM
MO568	Office Trailer South of 7th Street, East of Baltimore
MO577	AW Trailer - Phase III Double-Wide; West of 272-AW

Table 1. Non-Nuclear Facilities (This procedure is not applicable). (cont.)

Building #	Description
MO578	AW Trailer - Phase III Double-Wide; West of 272-AW
MO588	Mobile Office Five-Wide; West of 2704-HV
MO589	Mobile Office Five-Wide; West of 2704-HV
MO590	Mobile Office Five-Wide; West of 2704-HV
MO591	Mobile Office Five-Wide; West of 2704-HV
MO592	Mobile Office Double-Wide; West of 2704-HV
MO593	Mobile Office Double-Wide; West of 2704HV
MO594	Mobile Office Double-Wide; West of 2704-HV
MO595	Mobile Office Double-Wide; West of 2704-HV
MO596	C Farm Mobile Office Five-Wide; Buffalo and 7th St
MO597	C Farm Mobile Office Five-Wide; Buffalo and 7th St
MO598	C Farm Mobile Office Double-Wide; Buffalo and 7th St
MO599	C Farm Mobile Office Double-Wide; Buffalo and 7th St
MO633	Mobile Office - Sign Shop SW of 2704-HV
MO636	Lunchroom/Change room SE of 241S
MO648	222S Conference Trailer
MO667	Field Laboratory at Cold Test Facility - Rte 3 and Landfill N
MO689	Mobile Office Trailer SW of C-Farm
MO724	Mobile Office – Training SW of 2704HV
MO725	Mobile Office – Training SW of 2704HV
MO727	Office Trailer at LERF basins
MO730	Restroom Facility
MO732	Carpenter Shop Double-Wide; Akron Ave
MO733	Mobile Office - Teamster Shop/SW of 2704HV
MO734	Mobile Office - Pipefitter and Paint Shop - SW of 2704HV
MO742	Mobile Office at HWVP NE of 2704HV
MO815	CHANGE TRAILER - AT 241AP TANK FARM
MO816	CHANGE TRAILER - AT 244A
MO817	CHANGE TRAILER - AT TX TANK FARM
MO818	CHANGE TRAILER - AT 241AW TANK FARM
MO819	CHANGE TRAILER - AT SX TANK FARM
MO821	CHANGE TRAILER - AT 23RD AND CAMDEN
MO822	CHANGE TRAILER - AT 241C TANK FARM
MO823	CHANGE TRAILER - AT 241U 16TH AND CAMDEN
MO824	CHANGE TRAILER - AT 241BX TANK FARM
MO825	CHANGE TRAILER - N OF 2724B
MO826	CHANGE TRAILER - AT 241C TANK FARM
MO850	Maintenance and Calibration Shop East of 2704HV
MO890	Construction Trailer North of 2767E
TC272HV	F&P Equipment Storage NE of 272HV